

क्रमांक / PHE/2024/1141

दिनांक 8/8/2024

## Annexure C

### SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Mr. Rajesh Shrivastava** Designation **Executive Engineer P.H.E. SUB-DIVISION, DATIA** (Name of Officer with designation) from PHED inspected the **SSM RAM ANAMAYA WORLD SCHOOL, UNAO ROAD DATIA, DISTRICT & TEHSIL -DATIA**, Madhya-Pradesh 01/08/2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no 895 dated 01/08/2024 of PHED Department Sub Division Datia District – Datia (PHED Lab) certified that the **SSM RAM ANAMAYA WORLD SCHOOL, UNAO ROAD DATIA, DISTRICT & TEHSIL -DATIA**, Madhya-Pradesh ( Name of school & Address ) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.


This certificate is valid till 08/08/2026

Signature:

Seal:

Name :

Designation :

  
कार्यपालन यंत्री  
लोक स्वास्थ्य यांत्रिकी विभाग  
दतिया (म.प्र.)  
Rajesh Shrivastava  
Exe. Eng.

To,

SSM RAM ANAMAYA WORLD SCHOOL,  
UNAO ROAD DATIA (M.P)

# DISTRICT WATER TESTING LABORATORY

## (NATIONAL DRINKING WATER MISSION)

### ANALYSIS-REPORT

DISTRICT..... Datia..... BLOCK..... Datia....

#### PARTICULARS OF SAMPLE

S.No.	Tehsil	village	Location	Source
1	Datia	Datia	SSM RAM ANAMAYA WORLD SCHOOL Datia	T.w.
2				
3				
4				
5				

Date of Collection..... 1/8/24..... Date Receipt..... 1/8/24..... Date of Analysis... 2/8/24.....  
Sample submitted by Customer ssm ram anamaya world school

S.No.	Characteristics	Unit	Acceptable	Causes of Rejection	RESULTS				
					(1)	(2)	(3)	(4)	(5)

1.	<b>PHYSICAL</b>								
2.	Temperature	oC			25				
3.	Turbidity	NTU	2.5	10	1				
4.	Colour	Pt/Co	5.0	2.5	1				
5.	Test & odour	scale	Unobiedtionable		Unob				
6.	<b>CHEMICAL</b>								
7.	PH	PH scale	6.5 to 8.5	<6.5-8.65>	8.5				
8.	Conductivity	Mo.mhosh	-	-	480				
9.	Total Alkalinity	Mg/L	200Mg/L	600Mg/L	124				
10.	Chlorides	Mg/L	200Mg/L	1500Mg/L	36				
11.	Total Hardness as CaCo3	Mg/L	-	600Mg/L	48				
12.	Calcium Hardness as CaCO3	Mg/L	-	-	39				
13.	Megnesium Hardness as CaCO3	Mg/L	-	-	22				
14.	Total Dissolved Solid	Mg/L	500Mg/L	200Mg/L	54				
15.	Nitrate	Mg/L	45 Mg/L	45 Mg/L	10				
16.	Nitrites	Mg/L	Absence	Absew	Abs				
17.	Iron	Mg/L	0.1 Mg/L	0.3 Mg/L	0.3				
18.	Fluorides	Mg/L	1.0 Mg/L	1.5 Mg/L	0.1				
19.	Sulfate	Mg/L	-	400 Mg/L	24				
20.	Residual	Mg/L	-	-	Nil				
21.	Coagulant dose (Jartest)		-	-					
22.	<b>BACTERIOLOGICAL</b>								
23.	Coliform organism at	24Hrs/100ml			Nil				
24.	37.c(MP/100ml)	48Hrs/100ml							
25.	SPECIAL test								
26.	(i)Feecal								

Quality Manager  
Dist. Water Testing Lab  
P.H.E.D. Datia

NAME AND SIGNATURE OF  
LAB INCHARGE

7  
Prags  
Technical Manager  
Dist. Water Testing Lab  
P.H.E.D. Datia